

Funded by:



SOLAR ENERGY
TECHNOLOGIES OFFICE
U.S. Department Of Energy

Connector Reliability Across the US Solar Sector

2023 SETO PV Systems Workshop

October 12, 2023

Task 3. Techno-economic Analysis

SETO CPS Agreement # Sandia 38531 and NREL 39035


Principal Investigators: Laurie Burnham and Bruce King, Sandia National Laboratories

Other Contributors: Michael Bolen EPRI, Wayne Li ARNL, Michael Woodhouse, Jal Desai, Vignesh Ramasamy, NREL

Task 3. Techno-economic Analysis – NREL


#	Task/Subtask	Milestones – Project Duration	Status
Year	Techno-economic Analysis		
1	O&M model inputs and data	Inputs for a connector O&M cost-model identified, based on findings from industry surveys, onsite inspections and interviews, and laboratory analyses.	Complete, but industry interviews continuing
2	O&M cost model and validation	First draft of a O&M model to predict impact of replacement rates and the costs of replacing failed connectors (labor, system downtime, replacement purchases, etc.) along with other connector related items based on inspection and forensics work completed. Stakeholder review and revised connector O&M model	Draft TEA Model complete; internal stakeholder review initiated
3	TEA model and validation.	First draft of a techno-economic model to predict impact of connector degradation/failure on LCOE will be completed, with outputs from O&M cost model. Stakeholder review and revised connector LCOE techno-economic model and results.	Industry Review not started

Process for Connector Techno-Economic Evaluation



Types of Connectors

PV Module-to-Module Connector



Connector type described in 522 PV O&M Records (PV ROM)

CONNECTOR TYPE	
PV Module	277
Homerun	77
Power	43
Communication	42
Sensor	29
Y or T Connector	25
Fiber Optic	19
Harness	16
IDF Connector	11
Coolant Board	7
tracker control	2
WAGO	2
Fence	1

Harness: pre-cut, pre-terminated wiring

WORD OCCURRENCE IN 522 O&M WORK ORDERS (PVROM)

ENVIRONMENT CONDITION	
Water	18
Snow	9
Moisture	3
Lightning	3
Wind	1
Hurricane	1
Hail	1

CAUSE OF DAMAGE	
Recall	70
Install Error	24
Broken Modules	19
Mowing	10
Corrosion	10
Vegetation	9
Animal	4
Dirt	4


CONDITION OF CONNECTOR	
Ground Fault	136
Burn	90
Melt	56
Loose/Pulled	49
Arc Fault	40
Damage	40
Fire	32
Crimp	4

DETECTION OF FAILURE	
Inspect	86
Thermal/Infrared	74
UAS/UAV/Drone	52
Aerial	25

PVROM database contains site-level operations, maintenance, and production records from 6 industry partners for more than 50,000 O&M tickets at 837 sites in United States,

Connector O&M Costs

Example Failure Distributions



Activity Description	Mean Interval (years)	Weibull or Lognormal Shape Factor	Type of Distribution	Labor hrs per unit	Material/ Other Cost per unit
Repair Connector	38	1.09	Weibull	0.10	\$4
Replace Connector	20	1.43	Weibull	0.10	\$4
Reset Connector	123	1.15	Weibull	0.05	\$0
Modify Connector	532	0.84	Weibull	0.10	\$4
Inspect Connector	10		interval	0.01	\$0
Clean Connector	10		interval	0.05	\$0

Repair and Modify are assigned the same cost as Replace, even though they have different failure distributions from the PV ROM data. Replace both pin and sleeve sides.

DOWNTIME IN 522 O&M WORK ORDERS

Maintenance ticket close date minus open date.

Failure Category for Connectors	Median Downtime (Hours)	Mean Downtime (Hours)
Repair	190.9	759.8
Replace	226.5	1578.6
Reset	28.0	424.1
Modify	39.5	282.5
Other	331.3	1559.0

PV ROM Data from T. Gunda Sandia Natl Lab 1/18/2023; PVR0M database contains site-level operations, maintenance, and production records from 6 industry partners for more than 50,000 O&M tickets at 837 sites in United States,

LCOE represents Cost/Production.

8


System Name	100 MW Utility-Scale PV
Results	
Annualized O&M Costs (\$/year)	\$1,774,563
Annualized Unit O&M Costs (\$/kW/year)	\$17.75
Maximum Reserve Account	\$5,299,351
Net Present Value O&M Costs (project life)	\$27,923,565
Net Present Value (project life) per Wp	\$0.279
NPV Annual O&M Cost per kWh	\$0.016



Lifetime NPV by Component Type			
Component	Avg. Cost/Yr	NPV (Life)	% of Total
AC wiring	\$9,859	\$155,132	1%
Insurance	\$447,500	\$7,041,618	25%
Asset Management	\$610,731	\$9,610,140	34%
Cleaning/Veg	\$253,380	\$3,987,052	14%
DC wiring	\$18,417	\$289,805	1%
Connector	\$103,507	\$1,628,726	6%
Documents	\$22,952	\$361,155	1%
Electrical	\$6,719	\$105,722	0%
Inverter	\$84,302	\$1,326,529	5%
Mechanical	\$92,986	\$1,463,177	5%
Meter	\$16	\$248	0%
Monitoring	\$61	\$957	0%
PV Array	\$118,116	\$1,858,609	7%
PV module	\$5,570	\$87,641	0%
Roof	\$0	\$0	0%
Tracker	\$0	\$0	0%
Transformer	\$448	\$7,053	0%
(blank)	\$0	\$0	0%
Total	\$1,774,563	\$27,923,565	100%

Connectors about 6% of O&M cost.

Annual Costs associated with Connector Maintenance Cost and Lost Production
Example 100 MW PV Plant



Value of Lost Production due to Connector failure exceeds maintenance costs of Connectors.

Levelized Cost of Energy Analysis

LCOE

$$= \frac{I + \frac{F^n}{(1+R)^n} - \sum_{n=1}^N \frac{(D + DF)^n}{(1+R)^n} \times (T) - \frac{Rv^n}{(1+R)^n} \times (1 - T) + \sum_{n=1}^N \frac{O}{(1+R)^n} + \sum_{n=1}^N \frac{Pr}{(1+R)^n} + \sum_{n=1}^N \frac{Ir}{(1+R)^n}}{\sum_{n=1}^N \frac{P \times (1 - Dr)^n}{(1+R)^n}}$$

I = Initial Capital Investment

F = Follow-on investments (inverter, battery replacements)

D = Depreciation of assets (which may include depreciation from follow-on investments)

R = discount rate

T = Tax rate

O = PV system related O&M

Dr = Degradation PV

Rv = Residual value (if any)

P = Initial annual system production

Pr = Principal Payment

Ir = Interest Payment

Average connector related O&M cost (30 Years) – 1.29 \$/kWdc/yr (continuing 100 MW ground mount example)

Risks well beyond “lost production”

“Fire Department informed ...of a small fire on site...it is two connectors that are hanging from a rack and arcing. Utility notified and requested that they open their recloser immediately...the site was disconnected on the MV side.”

“called in..to report a fire due to a short circuit at the array. It was a small fire (smaller than a campfire)...extinguished with a fire extinguisher...fire is not active. Some damage to a module due to fire”

“We are an O&M company and have seen plenty of ... Ibad connectors overheating, melting, starting ground faults or arc fault fires...”



Question: How can we represent issues beyond connector COST and LOST PRODUCTION?

Thank you!!!

- Andy Walker PhD PE
- Jal Desai
- Vignesh Ramaswamy
- Andy.walker@nrel.gov

This work was authored [in part] by the National Renewable Energy Laboratory, operated by Alliance for Sustainable Energy, LLC, for the U.S. Department of Energy (DOE) under Contract No. DE-AC36-08GO28308. Funding provided by the U.S. Department of Energy Office of Energy Efficiency and Renewable Energy Solar Energy Technologies Office. The views expressed in the article do not necessarily represent the views of the DOE or the U.S. Government. The U.S. Government retains and the publisher, by accepting the article for publication, acknowledges that the U.S. Government retains a nonexclusive, paid-up, irrevocable, worldwide license to publish or reproduce the published form of this work, or allow others to do so, for U.S. Government purposes.